

2012 Consumer Confidence Report

15706647 LAKE DELTON WATERWORKS

Water System Information

If you would like to know more about the information contained in this report, please contact David Sterr at 608-253-9268. The water operator monitors your drinking water according to State and Federal Laws and the following information is for the period of January 1, 2012 to December 31, 2012.

The Village Board meets the second Monday of every month for the Regular Village Board Meeting at the Kay C Mackesey Administration Building at 4:00 P.M. Notices are usually posted at the Lake Delton Post Office, Lake Delton Branch of the Bank of Wisconsin Dells, Lake Delton National Bank, Kay C Mackesey Administration Building and on the Web at www.lakedelton.org.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791) or on their website: <http://water.epa.gov/drink/index.cfm> .

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source id	Source	Depth (in feet)	Status
1	Groundwater	400	Active
2	Groundwater	340	Active
3	Groundwater	400	Active
4	Groundwater	350	Active
5	Groundwater	360	Active
6	Groundwater	377	Active

To obtain a summary of the source water assessment please contact David Sterr at (608) 253-9268

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants:**

Such as viruses and bacteria, this may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

- **Inorganic contaminants:**

Such as salts and metals, which can be naturally- occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

- **Pesticides and herbicides:**

This may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.

- **Organic chemical contaminants:**

This includes synthetic and volatile organic chemicals, which are by-products of industrial processes, petroleum production, gas stations, urban storm water runoff and septic systems.

- **Radioactive contaminants:**

Which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Number of Contaminants Required to be Tested

This table displays the number of contaminants that were required to be tested in the last five years. The CCR may contain up to five years worth of water quality results. If a water system tests annually, or more frequently, the results from the most recent year are shown on the CCR. If testing is done less frequently, the results shown on the CCR are from the past five years.

Contaminant Group	# of Contaminants
Disinfection Byproducts	2
Inorganic Contaminants	16
Microbiological Contaminants	1
Radioactive Contaminants	3
Synthetic Organic Contaminants including Pesticides and Herbicides	25
Unregulated Contaminants	4
Volatile Organic Contaminants	20

Disinfection Byproducts

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2012)	Violation	Typical Source of Contaminant
HAA5 (ppb)	60	60	1	nd- 1	07/12/2010	No	
TTHM (ppb)	80	0	5.3	2.1- 5.3	07/12/2010	No	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2012)	Violation	Typical Source of Contaminant
BARIUM (ppm)	2	2	.016	.004- .016	02/10/2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM (ppb)	100	100	2	nd- 2	02/10/2011	No	Discharge from steel and pulp mills; Erosion of natural deposits
COPPER (ppm)	AL=1.3	1.3	.6650	0 of 10 results were above the action level.	06/23/2011	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
FLUORIDE (ppm)	4	4	.1	.1- .1	02/15/2011	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL (ppb)	100		1.3000	.6100- 1.3000	02/10/2011	No	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products.
NITRATE (NO ₃ -N) (ppm)	10	10	4.00	nd- 4.00		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SODIUM (ppm)	n/a	n/a	5.50	.85- 5.50	02/10/2011	No	n/a

Unregulated Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2012)	Violation	Typical Source of Contaminant
BROMODICHLOROMETHANE (ppb)	n/a	n/a	1.60	.56- 1.60	07/12/2010	No	n/a
BROMOFORM (ppb)	n/a	n/a	.33	nd- .33	07/12/2010	No	n/a
CHLOROFORM (ppb)	n/a	n/a	2.30	1.20- 2.30	07/12/2010	No	n/a
DIBROMOCHLOROMETHANE (ppb)	n/a	n/a	1.10	.32- 1.10	07/12/2010	No	n/a

Additional Health Information

Infants and young children are typically more vulnerable to **lead** in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791) or on their website: <http://water.epa.gov/drink/index.cfm>

Definition of Terms

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.